



US008938367B2

(12) **United States Patent**
Patel et al.

(10) **Patent No.:** **US 8,938,367 B2**
(45) **Date of Patent:** ***Jan. 20, 2015**

(54) **MOTION DETECTING DEVICE, METHOD OF PROVIDING THE SAME, AND METHOD OF DETECTING MOVEMENT**

(71) Applicant: **Georgia Tech Research Corporation**,
Atlanta, GA (US)

(72) Inventors: **Shwetak N. Patel**, Seattle, WA (US);
Matthew S. Reynolds, Durham, NC (US);
Gregory D. Abowd, Atlanta, GA (US)

(73) Assignee: **Georgia Tech Research Corporation**,
Atlanta, GA (US)

(*) Notice: Subject to any disclaimer, the term of this patent is extended or adjusted under 35 U.S.C. 154(b) by 0 days.

This patent is subject to a terminal disclaimer.

(21) Appl. No.: **13/923,625**

(22) Filed: **Jun. 21, 2013**

(65) **Prior Publication Data**

US 2013/0289930 A1 Oct. 31, 2013

Related U.S. Application Data

(63) Continuation of application No. 12/778,771, filed on May 12, 2010.

(60) Provisional application No. 61/177,482, filed on May 12, 2009.

(51) **Int. Cl.**

G01L 7/00 (2006.01)

G01L 13/00 (2006.01)

(Continued)

(52) **U.S. Cl.**

CPC **G01L 13/00** (2013.01); **B01D 46/10** (2013.01); **F24F 11/0012** (2013.01); **F24F 11/0034** (2013.01); **G08B 13/20** (2013.01); **F24F 2011/0036** (2013.01)

USPC **702/138**; 702/45; 702/47; 702/50; 702/57

(58) **Field of Classification Search**

USPC 702/45, 47, 50, 57, 138; 340/540; 165/59; 96/417, 421

See application file for complete search history.

(56) **References Cited**

U.S. PATENT DOCUMENTS

3,714,516 A 1/1973 Howe
4,612,617 A 9/1986 Laplace, Jr. et al.

(Continued)

FOREIGN PATENT DOCUMENTS

CN 101680676 3/2010
DE 102007032053 1/2009

(Continued)

OTHER PUBLICATIONS

Drenker et al., Nonintrusive Monitoring of electrical Loads, IEEE Xplore, 5 pages. Oct. 1999. Oct. 1, 1999.
(Continued)


Primary Examiner — Elias Desta

(74) *Attorney, Agent, or Firm* — Bryan Cave LLP

(57) **ABSTRACT**

In some embodiments, a motion detecting device is configured to detect whether one or more movement events have occurred. The motion detecting device can include: (a) a processing module configured to run on a computational unit; and (b) a sensing device having: (1) one or more pressure sensors configured to provide two or more pressure measurements; and (2) a transmitter electrically coupled to the one or more pressure sensors and configured to transmit the two or more pressure measurements to the computational unit. The processing module is configured to use the two or more pressure measurements to determine whether the one or more movement events have occurred. The sensing device can be configured to be placed in at least one of ductwork of a heating, ventilation, and air conditioning system or an air handler of the heating, ventilation, and air conditioning system. Other embodiments are disclosed.

29 Claims, 13 Drawing Sheets



(51) **Int. Cl.**

B01D 46/10 (2006.01)
F24F 11/00 (2006.01)
G08B 13/20 (2006.01)

(56)

References Cited

U.S. PATENT DOCUMENTS

4,804,957 A 2/1989 Selph et al.
 4,858,141 A 8/1989 Hart et al.
 5,276,629 A 1/1994 Reynolds
 5,409,037 A 4/1995 Wheeler et al.
 5,441,070 A 8/1995 Thompson
 5,483,153 A 1/1996 Leeb et al.
 5,590,179 A 12/1996 Shincovich et al.
 5,636,895 A 6/1997 Murr
 5,717,325 A 2/1998 Leeb et al.
 5,898,387 A 4/1999 Davis et al.
 6,275,168 B1 8/2001 Slater et al.
 6,728,646 B2 4/2004 Howell et al.
 6,816,078 B2 11/2004 Onoda et al.
 6,839,644 B1 1/2005 Bryant et al.
 6,853,291 B1 2/2005 Aisa
 6,906,617 B1 6/2005 Van de Meulen
 7,019,666 B2 3/2006 Tootoonian Mashhad et al.
 7,043,380 B2 5/2006 Rodenberg, III et al.
 7,244,294 B2 7/2007 Kates
 7,276,915 B1 10/2007 Euler et al.
 7,400,986 B2 7/2008 Latham et al.
 7,460,930 B1 12/2008 Vinson et al.
 7,493,221 B2 2/2009 Caggiano et al.
 7,498,935 B2 3/2009 Kodoma et al.
 7,546,214 B2 6/2009 Rivers, Jr. et al.
 7,612,971 B2 11/2009 Premierlani et al.
 7,656,649 B2 2/2010 Loy et al.
 7,702,421 B2 4/2010 Sullivan et al.
 7,873,449 B2* 1/2011 Bujak et al. 701/33.7
 8,199,005 B2 6/2012 Thomas et al.
 8,219,250 B2 7/2012 Dempster et al.
 2001/0003286 A1 6/2001 Philippbar et al.
 2002/0010690 A1 1/2002 Howell et al.
 2003/0050737 A1 3/2003 Osann et al.
 2003/0088527 A1 5/2003 Hung et al.
 2003/0097348 A1 5/2003 Cao
 2003/0193405 A1 10/2003 Hunt et al.
 2004/0128034 A1 7/2004 Carroll et al.
 2004/0140908 A1 7/2004 Gladwin et al.
 2004/0206405 A1 10/2004 Villeneuve et al.
 2005/0060107 A1 3/2005 Rodenberg, III et al.
 2005/0067049 A1 3/2005 Fima et al.
 2006/0009928 A1 1/2006 Addink et al.
 2006/0077046 A1 4/2006 Endo
 2006/0195275 A1 8/2006 Latham et al.
 2006/0245467 A1 11/2006 Casella et al.
 2008/0079437 A1 4/2008 Berkcan et al.
 2008/0086394 A1 4/2008 O'Neil et al.
 2008/0091345 A1 4/2008 Patel et al.
 2008/0224892 A1 9/2008 Bogolea et al.
 2008/0255782 A1 10/2008 Bilac et al.
 2009/0045804 A1 2/2009 Durling et al.
 2009/0072985 A1 3/2009 Patel et al.
 2009/0295578 A1* 12/2009 Gantt 340/544
 2010/0030393 A1 2/2010 Masters et al.
 2010/0070214 A1 3/2010 Hyde et al.
 2010/0070218 A1 3/2010 Hyde et al.
 2010/0109842 A1 5/2010 Patel et al.
 2010/0188262 A1 7/2010 Reymann et al.
 2010/0288468 A1* 11/2010 Patel et al. 165/59
 2011/0004421 A1 1/2011 Rosewell et al.

FOREIGN PATENT DOCUMENTS

EP 1136829 9/2001
 FR 2645968 A 10/1990
 WO 9304377 3/1993
 WO 2009081407 7/2009
 WO 2010007369 1/2010

OTHER PUBLICATIONS

Hart, Nonintrusive Appliance Load Monitoring, IEEE Xplore, 22 pages. Dec. 1992. Dec. 1, 1992.
 Murata et al., Estimation of Power Consumption for Household Electric Appliances, Proceedings of the 9th International Conference on Neural Information Processing (ICONIP'02), vol. 6, 5 pages. 2002. Nov. 19, 2013.
 Prudenzi, A Neuron Nets Based Procedure for Identifying Domestic Appliances Pattern-of-Use from Energy Recordings at Meter Panel, IEEE, 6 pages. 2002. Nov. 19, 2013.
 Laughman et al., Power Signature Analysis, IEEE, 8 pages. Mar./Apr. 2003. Nov. 19, 2013.
 The Value of Disaggregated Feedback, 1 page. Nov. 19, 2013.
 Horst, G., Whirlpool Corporation; Woodridge Energy Study and Monitoring Pilot. pp. 1099. 2006.56ty76 Nov. 19, 2013.
 Study Finds Elder Care a Growing Emotional and Financial Burden for Baby Boomers New ADT Monitoring Service for Elderly Helps Ease the Stress of Long Distance Care Giving, 4 pages. 2005. Nov. 19, 2013.
 Ninomura, P., Rousseau, C., Bartley, J., Guidelines for Design and Construction of Hospital and Health Care Facilities, Rx for Health-Care HVAC—A Supplement to ASHRAE Journal, pp. H33-H37. 2006. Nov. 19, 2013.
 Tapia, E., Activity Recognition in the Home Setting Using Simple and Ubiquitous Sensors, In the Proceedings of Pervasive 2004, pp. 158-175. 2004. Nov. 19, 2013.
 Bian, X., Abowd, G., Rehg, J., Using Sound Source Localization to Monitor and Infer Activities in the Home, In the Proceedings of the Pervasive 2005, pp. 19-26, 2005. Nov. 19, 2013.
 Beckmann, C., Consolvo, S., and LaMarca, A., Some Assembly Required: Supporting End-User Sensor Installation in Domestic Ubiquitous Computing Environments, In the Proceedings of Ubicomp 2004, pp. 107-124. 2004. Jan. 1, 2004.
 Chen, J., Kam, A., Zhang, J., Liu, N., Shue, L., Bathroom Activity Monitoring Based on Sound, In the Proceedings of Pervasive 2005, pp. 47-61. 2005. Jan. 1, 2005.
 Chetty, M., Sung, J., Grinter, R., How Smart Homes Learn: The Evolution of the Networked Home and Household, In the Proceedings of Ubicomp 2007, pp. 127-144. 2007. Jan. 1, 2007.
 Fogarty, J., Au, C., and Hudson, S., Sensing from the Basement: A Feasibility Study of Unobtrusive and Low-Cost Home Activity Recognition, In the Proceedings of ACM Symposium on User Interface Software and Technology 2006, pp. 91-100. 2006. Jan. 1, 2006.
 Hirsch, T., Forlizzi, J., Hyder, E., Goetz, J., Kurtz, C., Strobach, J., The ELDER Project: Social and Emotional Factors in the Design of Eldercare Technologies, Conference on Universal Usability 2000, pp. 72-79. 2000. Jan. 1, 2000.
 Mountain, D., Price Influences Demand, DeGroote School of Business, McMaster University, 16 pages. 2008. Jan. 1, 2008.
 Intersema MS5536 Product Sheet. 2007. Jan. 1, 2007.
 Koile, K., Tollmar, K., Demirdjian, D., shrobe, H., and Darrell, T., Activity Zones for Context-Aware Computing, In the Proceedings of UbiComp 2003, pp. 90-106. 2003. Jan. 1, 2003.
 Nishimura, T., "Heat Pumps—Status and Trends" in Asia and the Pacific, International Journal of Refrigeration, pp. 405-413. 2000. Jan. 1, 2000.
 Nadel, S., Increasing Appliance Energy Savings by Looking Beyond the Current Energy Star, ACEEE, 25 pages. 2004. Jan. 1, 2004.
 Ninomura, P., Bartley, J., New Ventilation Guidelines for Health Care Facilities, ASHRAE Journal, pp. 29-33. 2002. Jan. 1, 2002.
 Orr, R. and Abowd, G., The Smart Floor: A Mechanism for Natural User Identification and Tracking, In the Proceeding of the 2000 Conference on Human Factor in Computing Systems, 9 pagesp. 2000. Jan. 1, 2000.
 Rowan, J., Mynatt, E., Digital Family Portrait Field Trial: Support for Aging in Place, In the Proceeding of the 2009 Conference on Human Factor in Computing Systems: Assistive Appliances, pp. 521-530. 2005. Jan. 1, 2005.
 Froehlich, J., Everitt, K., Fogarty, J., Patel, S., Landay, J., Sensing Opportunities for Personalized Feedback Technology to Reduce Consumption. UW CSE Technical Report: CSE Sep. 13, 2001, 7 pages. 2009.6 Jan. 1, 2009.

(56)

References Cited**OTHER PUBLICATIONS**

Tapia, E., Activity Recognition in the Home Setting Using Simple and Ubiquitous Sensors, Master's Thesis. 2003. Jan. 1, 2003.

Wilson, D., Atkeson, C., STAR: Simultaneous Tracking and Activity Recognition Using Many Anonymous Binary Sensors. Pervasive 2005, pp. 2005. Jan. 1, 2005.

Wren, C. and Munguia-Tapia, E., Toward Scalable Activity Recognition for Sensor Networks. In the Proceedings of LoCA 2006, pp. 168-185. 2006. Jan. 1, 2006.

Yang, Z. and Bobick, A., Visual Integration from Multiple Cameras, In the Proceedings of WACV/MOTION 2005, pp. 488-493. 2005. Jan. 1, 2005.

Patel, S.N., Robertson, T., Kientz, J.A., Reynolds, M.S., Abowd, G.D.: At the Flick of a Switch: Detecting and Classifying Unique Electrical Events on the Residential Power Line. In the Proceedings of Ubicomp 2007, pp. 271-288. 2007. Jan. 1, 2007.

Patel, S., Truong, K., Abowd, G., PowerLine Positioning: A Practical Sub-Room-Level Indoor Location System for Domestic Use, In the Proceedings of Ubicomp 2006, pp. 441-458. 2006. Jan. 1, 2006.

Patel, S., Bringing Sensing to the Masses: An Exploration in Infrastructure-Mediated Sensing (slides and transcript of presentation), Intel Labs Seattle, Washington, 133 pages. Apr. 28, 2008. Apr. 28, 2008.

Tapia, E.M., Intille, S.S., Lopez, L., Larson, K.: The design of a portable kit of wireless sensors for naturalistic data collection. In the Proceedings of Pervasive 2006. LNCS, vol. 3968, pp. 117-134. 2006. Jan. 1, 2006.

Iachello, G., Abowd, G.D.: Privacy and Proportionality: Adapting Legal Evaluation Techniques to Inform Design in Ubiquitous Computing. In the Proceedings of CHI 2005, pp. 91-100. 2005. Jan. 1, 2005.

Patel, S., Gupta S., and Reynolds M., End-User-Deployable Whole House Contact-Less Power Consumption Sensing, UbiComp 2009, 4 pages. 2009. Jan. 1, 2009.

Mountain, D., SUMMARY The Impact of Real-Time Feedback on Residential Electricity Consumption: The Hydro One Pilot, 4 pages. 2006. Jan. 1, 2006.

Darby, S., Making it Obvious: Designing Feedback into Energy Consumption, Proceedings of the Second International Conference on Energy Efficiency in Household Appliances and Lighting, 11 pages. 2000. Jan. 1, 2000.

Froehlich, J., Sensing and Feedback of Everyday Activities to Promote Environmentally Sustainable Behaviors, Thesis Proposal, Computer Science and Engineering, University of Washington, 35 pages. 2009. Jan. 1, 2009.

Brandon, G., Lewis, A., Reducing Household Energy Consumption: A Qualitative and Quantitative Field Study, Journal of Environmental Psychology, pp. 75-85. 1999. Jan. 1, 1999.

Parker, D., Hoak, D., Cummings, J., Contract Report: Pilot Evaluation of Energy Savings from Residential Energy Demand Feedback Devices, Florida Solar Energy Center, A Research Institute of the University of Central Florida, 32 pages. 2008. Jan. 1, 2008.

Ueno, T., Inada, R., Saeki, O., Tsuji, K., Effectiveness of Displaying Energy Consumption Data in Residential Houses Analysis on How the Residents Respond, ECEEE 2005 Summer Study—What Works and Who Delivers?, pp. 1289-1299. 2005. Jan. 1, 2005.

Arvola, A., Uutela, A., Anttila, U., Billing Feedback as a Means to Encourage Household Electricity Conservation: A Field Experiment in Helsinki, Proceedings of the 1993 Summer Study of the European Council for Energy Efficient Economy, pp. 11-21. 2003. Jan. 1, 2003.

Darby, S., The Effectiveness of Feedback on Energy Consumption, Environmental Change Institute, University of Oxford, 21 pages. 2006. Jan. 1, 2006.

Fischer, C., Feedback on Household Electricity Consumption: A Tool for Saving Energy?, Energy Efficiency, pp. 79-104. 2008. Jan. 1, 2008.

* cited by examiner

FIG. 1
100




FIG. 2




FIG. 3
360




FIG. 4
400




FIG. 5
500




FIG. 6




FIG. 7




FIG. 8


800

FIG. 9


900

FIG. 10**Table 1.** Descriptions of the homes in which the system was tested. The deployment lasted approximately 3-4 weeks.

Home	Year Built	No. of HVAC Units Tested	Floors/ Total Size (Sq Ft) /Sq M)	Style/ No. of occupants	Bedrooms/ Bathrooms/ Total Rms./ Doorways considered	Deploy Length (weeks)
1	2003	3	3/4000/371	1 Family Home/3	4/4/13/20	4
2	2001	1	1/1600/149	1 Family Home/5	3/2/7/10	3
3	1997	1	1/700/58	1 Bed Apt/2	1/1/5/5	3
4	1986	1	1/500/46	1 Bed Studio/1	1/1/3/4	4

FIG. 11**Table 2.** Performance results of the manually-labeled experiments with the HVAC in operation. The accuracies are shown using 10-fold cross validation.

Home/ Floor	No. of Doorways Tested	No. of Door Instances/ People Instances	Door Majority Classif. (%)	Door Classif. Accuracy (%)	People Majority Classif. (%)	People Classif. Accuracy (%)
1/1	5	375/375	21	84	23	72
1/2	4	300/300	18	61	18	42
1/3	11	825/600	9	77	12	61
2	10	750/400	8	73	10	63
3	5	375/375	20	74	20	70
4	4	300/300	26	81	25	76

FIG. 12

Table 3. Confusion matrix of the classification results from the controlled experiments in Home 1/3 (HVAC in operation). D1-D11 represent each doorway.

	D1	D2	D3	D4	D5	D6	D7	D8	D9	D10	D11
D1	<u>72</u>	0	0	0	1	0	0	1	0	0	1
D2	1	<u>57</u>	0	2	0	2	6	4	0	1	2
D3	0	1	<u>60</u>	1	0	1	3	2	5	2	0
D4	0	0	1	<u>57</u>	2	0	0	4	3	6	2
D5	4	0	1	4	<u>52</u>	5	0	6	2	0	1
D6	5	1	0	0	6	<u>53</u>	4	2	0	1	3
D7	0	2	3	3	0	1	<u>61</u>	0	3	2	0
D8	6	0	0	0	2	1	1	<u>55</u>	5	0	5
D9	1	0	4	0	1	5	2	0	<u>59</u>	2	1
D10	2	2	7	0	3	3	8	0	2	<u>43</u>	5
D11	0	1	0	0	0	2	0	0	0	2	<u>70</u>

FIG. 13

Table 4. Performance results of the manually labeled door open/close events for when the HVAC is not in operation

Home/ Floor	No. of Doorways Tested	No. of Door Event Instances	Door Majority Classif. (%)	Door Classif. Accuracy (%)
1/1	5	125	20	66
1/2	4	100	25	47
1/3	11	275	9	64
2	10	250	10	69
3	5	125	20	71
4	4	100	25	68

FIG. 14

Table 5. The percentage of events that the system was able to detect. This is determined by comparing the number of detected events to the number of doorway events gathered by the motion sensors. The results include events detected with HVAC both on and off.

Home/ Floor	No. of Doorways Tested	No. of Total Motion Sensor Events	No. of Total Detected Events	HVAC On: Detected Events (%)	HVAC Off: Detected Events (%)
1/1	5	53	48	91	68
1/2	4	94	60	64	35
1/3	11	238	195	82	73
2	10	467	334	72	64
3	5	245	198	81	70
4	4	61	51	84	77

FIG. 15

Table 6. The performance of using the learning approach to the data from the long-term deployment. The motion sensor data was used to label each event, so the dataset consists of *in situ* event instances. The accuracies are shown using 10-fold cross validation.

Home/ Floor	No. of Doorways Tested	No. of Doorway Transition Instances	Door Majority Classif. (%)	Door Classif. Accuracy (%)	People Majority Classif. (%)	People Classif. Accuracy (%)
1/1	5	48	26	65	28	61
1/2	4	60	26	53	26	42
1/3	11	195	14	72	17	63
2	10	334	19	62	12	65
3	5	198	28	72	23	71
4	4	51	34	78	38	81

FIG. 16





FIG. 17



1

MOTION DETECTING DEVICE, METHOD OF PROVIDING THE SAME, AND METHOD OF DETECTING MOVEMENT

CROSS-REFERENCE TO RELATED APPLICATIONS

This application claims is a continuation of U.S. patent application Ser. No. 12/778,771, filed May 12, 2010. U.S. patent application Ser. No. 12/778,771 claims priority from U.S. Provisional Application No. 61/177,482, filed May 12, 2009. U.S. patent application Ser. No. 12/778,771 and U.S. Provisional Application No. 61/177,482 is incorporated herein by reference

FIELD OF THE INVENTION

This invention relates generally to apparatuses and methods for detecting movement events, and relates more particularly to such apparatuses and methods that detecting movement events using heating, ventilation, and air conditioning (HVAC) systems.

DESCRIPTION OF THE BACKGROUND

Development of low-cost and easy-to-deploy sensing systems to support movement detection in a home or another building has been an active research area. Much of the development has centered on the deployment of a network of inexpensive sensors throughout the home, such as motion detectors or simple contact switches. Although these solutions are cost-effective on an individual sensor basis, they are not without some important drawbacks that limit the likelihood of eventual commercial success through broad consumer acceptance.

Commonly used sensors for detecting human activity in the home include high-fidelity sensors such as visible light and infrared (IR) cameras or microphones, as well as low-fidelity sensors such as passive infrared (PIR) motion detectors and floor weight sensors. High-fidelity distributed direct sensing has a long history of use in activity detection and classification research, primarily focused on computer vision or machine learning systems that capture the movement of people in spaces. The use of these high fidelity sensors in certain spaces often raises concerns about the balance between value-added services and acceptable surveillance, particularly in home settings. Low-fidelity, distributed direct sensing systems use of a large collection of simple, low cost sensors, such as motion detectors, pressure mats, break beam sensors, and contact switches.

All distributed direct sensing approaches share the advantages and disadvantages of placing each sensor in close proximity to where human activity occurs. For example, commonly used cameras or PIR sensors require a clear line of sight to the desired room coverage area. That is, the person being sensed will be able to see the camera or PIR sensor. Generally, cameras or PIR sensors when deployed on walls, on ceilings, or above a door have adverse aesthetics effects on the area around where the cameras or PIR sensors are deployed. Furthermore, the large number of sensors required for coverage of an entire building presents an inherent complexity hurdle. Installation and maintenance of (typically) tens of sensors in a home, or hundreds to thousands of sensors in a larger building such as a hotel, hospital, or assisted living facility, results in high costs during installation and operation.

It is often difficult to balance the value of in-home sensing and the complexity of the sensing infrastructure. One

2

example that illustrates this difficulty is the Digital Family Portrait system, a peace of mind application for communicating well-being information from an elderly person's home to a remote caregiver. In the system's deployment study, movement data was gathered from a collection of strain sensors attached to the underside of the first floor of an elder's home. The installation of these sensors was difficult, time-consuming, and required direct access to the underside of the floor. Though the value of the application was proven, the complexity and cost of the sensing limited the number of homes in which the system could be deployed easily.

Accordingly, a need or potential for benefit exists for an apparatus and/or method that allows detection of movement events without the high cost and installation complexity of currently available motion detection systems and methods.

BRIEF DESCRIPTION OF THE DRAWINGS

To facilitate further description of the embodiments, the following drawings are provided in which:

FIG. 1 illustrates a block diagram of a motion detecting device, according to a first embodiment;

FIG. 2 illustrates an implementation of sensor units of the motion detecting device of FIG. 1 in an exemplary heating, ventilation, and air conditioning (HVAC) system, according to the first embodiment;

FIG. 3 illustrates another view of the exemplary HVAC system of FIG. 2 in an exemplary home, according to the first embodiment;

FIG. 4 shows a graph of the change in static pressure versus time as a door is opened and closed, according to an embodiment;

FIG. 5 shows a graph of the change in static pressure versus time as people walk through a doorway, according to an embodiment;

FIG. 6 illustrates an implementation of a sensing device of a motion detecting device in an exemplary HVAC system, according to a second embodiment;

FIG. 7 illustrates an implementation of a sensing device of a motion detecting device in an exemplary HVAC system, according to a third embodiment;

FIG. 8 illustrates a flow chart for an embodiment of a method of providing a motion sensor, according to an embodiment;

FIG. 9 illustrates a flow chart for an embodiment of a method of detecting movement, according to an embodiment;

FIG. 10 illustrates a chart of descriptions of homes used to test an example of a motion detecting device, according to an embodiment;

FIG. 11 illustrates a chart of results of a first experiment using an example of a motion detecting device, according to an embodiment;

FIG. 12 illustrates a chart of a confusion matrix for the results of the first experiment using the same example of the motion detecting device, according to an embodiment;

FIG. 13 illustrates a chart of results of a second experiment using the same example of the motion detecting device, according to an embodiment;

FIG. 14 illustrates a chart of results of the first and second experiment using the same example of the motion detecting device, according to an embodiment;

FIG. 15 illustrates a chart of results of a third experiment using the same example of the motion detecting device, according to an embodiment;

FIG. 16 illustrates a computer that is suitable for implementing an embodiment of computer system of FIG. 1; and

FIG. 17 illustrates a representative block diagram of an example of the elements included in the circuit boards inside chassis of the computer of FIG. 16.

For simplicity and clarity of illustration, the drawing figures illustrate the general manner of construction, and descriptions and details of well-known features and techniques may be omitted to avoid unnecessarily obscuring the invention. Additionally, elements in the drawing figures are not necessarily drawn to scale. For example, the dimensions of some of the elements in the figures may be exaggerated relative to other elements to help improve understanding of embodiments of the present invention. The same reference numerals in different figures denote the same elements.

The terms “first,” “second,” “third,” “fourth,” and the like in the description and in the claims, if any, are used for distinguishing between similar elements and not necessarily for describing a particular sequential or chronological order. It is to be understood that the terms so used are interchangeable under appropriate circumstances such that the embodiments described herein are, for example, capable of operation in sequences other than those illustrated or otherwise described herein. Furthermore, the terms “include,” and “have,” and any variations thereof, are intended to cover a non-exclusive inclusion, such that a process, method, system, article, device, or apparatus that comprises a list of elements is not necessarily limited to those elements, but may include other elements not expressly listed or inherent to such process, method, system, article, device, or apparatus.

The terms “left,” “right,” “front,” “back,” “top,” “bottom,” “over,” “under,” and the like in the description and in the claims, if any, are used for descriptive purposes and not necessarily for describing permanent relative positions. It is to be understood that the terms so used are interchangeable under appropriate circumstances such that the embodiments of the invention described herein are, for example, capable of operation in other orientations than those illustrated or otherwise described herein.

The terms “couple,” “coupled,” “couples,” “coupling,” and the like should be broadly understood and refer to connecting two or more elements or signals, electrically, mechanically and/or otherwise. Two or more electrical elements may be electrically coupled but not be mechanically or otherwise coupled; two or more mechanical elements may be mechanically coupled, but not be electrically or otherwise coupled; two or more electrical elements may be mechanically coupled, but not be electrically or otherwise coupled. Coupling may be for any length of time, e.g., permanent or semi-permanent or only for an instant.

“Electrical coupling” and the like should be broadly understood and include coupling involving any electrical signal, whether a power signal, a data signal, and/or other types or combinations of electrical signals. “Mechanical coupling” and the like should be broadly understood and include mechanical coupling of all types. The absence of the word “removably,” “removable,” and the like near the word “coupled,” and the like does not mean that the coupling, etc. in question is or is not removable.

DETAILED DESCRIPTION OF EXAMPLES OF EMBODIMENTS

In some embodiments, a motion detecting device is configured to detect whether one or more movement events have occurred. The motion detecting device can include: (a) a processing module configured to run on a computational unit; and (b) a sensing device having: (1) one or more pressure sensors configured to provide two or more pressure measure-

ments; and (2) a transmitter electrically coupled to the one or more pressure sensors and configured to transmit the two or more pressure measurements to the computational unit. The processing module is configured to use the two or more pressure measurements to determine whether the one or more movement events have occurred. The sensing device is configured to be placed in at least one of ductwork of a heating, ventilation, and air conditioning system or an air handler of the heating, ventilation, and air conditioning system.

In further embodiments, a method of detecting movement can include: performing two or more first measurements of air pressure in a duct of a heating, ventilation, and air conditioning system; transmitting the two or more first measurements of the air pressure; determining one or more first changes of the air pressure based on the two or more first measurements of the air pressure; and associating at least one of the one or more first changes of the air pressure with a first movement event.

In other embodiments, a method of providing a motion sensor includes: providing one or more pressure sensors configured to provide two or more pressure measurements; providing a transmitter; electrically coupling the transmitter to the one or more pressure sensors; providing a body; mechanically coupling the one or more pressure sensors and the transmitter to the body; and providing a processing module configured to run on a computational unit, the processing module having an event detection module configured to use the two or more pressure measurements to determine whether one or more movement events have occurred.

In still other embodiments, an air filter unit can include: (a) an air filter having: (1) a filter material; (2) an outer frame located around the filter material; (3) at least one pressure sensor disposed proximate to at least one of the filter material or the outer frame and configured to provide two or more pressure measurements; and (4) a transmitter electrically coupled to the at least one pressure sensor; and (b) a processing module configured to run on a computational unit, the processing module configured to determine an occurrence of one or more movement events based on the two or more pressure measurements of the at least one pressure sensor.

In yet further embodiments, a heating, ventilation, and air conditioning system can include: (a) an air handler; (b) at least one pressure sensor located at the air handler; and (c) a processing module configured to run on a computational unit. The processing module is electrically coupled to the at least one pressure sensor via the computational unit and configured to determine the occurrence of one or more movement events based on two or more pressure measurements of the at least one pressure sensor.

Turning to the drawings, FIG. 1 illustrates a block diagram of a motion detecting device 100, according to a first embodiment. FIG. 2 illustrates an implementation of sensor units 130 and 131 of motion detecting device 100 in an exemplary HVAC system 250, according to the first embodiment. FIG. 3 illustrates another view of exemplary heating, ventilation, or air conditioning (HVAC) system 250 in an exemplary residential setting 360, according to the first embodiment. Motion detecting device 100 is merely exemplary and is not limited to the embodiments presented herein. Motion detecting device 100 can be employed in many different embodiments or examples not specifically depicted or described herein. For example, motion detecting device 100 can be deployed in HVAC systems in a commercial or residential setting not specifically depicted or described herein. In some embodiments, an electrical device or motion detecting device 100 can be configured to detect when one or more movement events have occurred.

Some embodiments provide a whole-house or whole-building system and method for detecting gross movement and room transitions by sensing differential air pressure at a single point in the house or building. This system and method can leverage the central heating, ventilation, and air conditioning (HVAC) systems found in many homes and buildings

To aid understanding of motion detecting device 100, the home can be considered a closed circuit for air circulation, where HVAC system 250 provides a centralized airflow source and therefore a convenient single monitoring point for the whole airflow circuit. Disruptions in home airflow caused by human movement through a house or building, especially those caused by the blockage of doorways and thresholds, results in static pressure changes in an air handler 253 (FIGS. 2 and 3) of HVAC system 250 when the HVAC system 250 is operating.

In a simple, but not limiting example, motion detecting device 100 detects and records static pressure changes in air handler 253 (FIGS. 2 and 3) of HVAC system 250 using pressure sensors 112 and 114 (FIG. 1) mounted at air filter 252 (FIG. 2). Motion detecting device 100 can classify where certain movement events are occurring in a house or building, such as an adult walking through a particular doorway or the opening and closing of a particular door. Motion detecting device 100 also is capable of detecting movement events when the HVAC system 250 is not operating. Furthermore, by observing the opening and closing of doors and the movement of people transitioning from room to room and/or by training motion detecting device 100, the location and activity of people in the space can be inferred by motion detecting device 100. In addition, detecting a series of room transitions can be used by motion detecting device 100 for simple occupancy detection or to estimate a person's path in a house or building.

An advantage of this approach, when compared to installing motion sensors throughout an entire house, is that it requires the installation of only a single or small number of sensing devices 110 that are wirelessly coupled to a computational unit 120 (FIG. 1). Installing and maintaining a single or small number of sensing devices 110 instead of ten or hundreds of motion sensors that can be required by other systems can save a significant amount of money and manpower.

Referring to FIGS. 1-2, motion detecting device 100 can include: (a) a sensing device 110 configured to be placed in ductwork of HVAC system 250; and (b) computational unit 120. Sensing device 110 can include: (a) one or more sensor units 130 and 131; (b) a transceiver or transmitter 116; (c) a power source 117; (d) a controller 118 with memory 119; and (e) a coupling device 132.

In some examples, sensor unit 130 can include pressure sensor 112 and a temperature sensor 113. Sensor unit 131 can include pressure sensor 114 and a temperature sensor 115. Sensor units 130 and 131 can be configured such that temperature sensors 113 and 115 measure a temperature at pressure sensors 112 and 114. In some examples, sensor units 130 and 131 can include temperature sensors 113 and 115 to calibrate pressure sensors 112 and 114, respectively. In some examples, more than two pressure sensors can be used. Using multiple sensor distributed across the sensing area (e.g., an air filter) can improve the accuracy of the measurements and thus, the detection of movement events.

In some embodiments, pressure sensors 112 and 114 can be differential pressure sensors. In the same or different embodiments, pressure sensors 112 and 114 can be absolute pressure sensors. In various embodiments, pressure sensors 112 and 114 can have a resolution of 0.1 millibar, provide a stable output of up to two bars, and have a maximum rating of up to

five bars. For example, sensor units 130 and 131 can be Intersema MS5536 piezoresistive pressure sensor modules, manufactured by MEAS Switzerland SA. Intersema MS5536 piezoresistive pressure sensor modules include both a pressure sensor and a temperature sensor along with a built-in analog-to-digital (A/D) converter. In other examples, sensor units 130 and 131 include pressure sensors 112 and 114, but not temperature sensors 113 and 115, respectively. In the same or different example, sensor units 130 and 131 do not have any A/D converters, which can be contained within controller 118.

In some examples, controller 118 can be configured to receive pressure and temperature measurements from sensor units 130 and 131. In some examples, controller 118 can perform some processing of the pressure and temperature measurements before communicating information about the pressure measurements to computational unit 120 via transmitter 116.

In some examples, controller 118 can sample pressure sensors 112 and 114 and temperature sensors 113 and 115 at predetermined intervals. In some embodiments, controller 118 can sample the pressure and temperature measurements every 20 milliseconds to 100 milliseconds (e.g., 35 milliseconds). That is, each of pressure sensors 112 and 114 can be configured to provide a series of pressure measurements to controller 118 and/or transmitter 116. For example, each of pressure sensors 112 and 114 can provide a first pressure measurement at a first time, a second pressure measurement at a second time, and a third pressure measurement at a third time, where the first time is before the second time and third time and where the second time is before the third time.

After sampling the temperature and pressure measurements, controller 118 can calculate a temperature-compensated pressure value for each of sensor units 130 and 131. In some examples, a temperature compensation formula or temperature compensation information provided by the manufacturer of pressure sensors 112 and 114 can be used to calculate the temperature-compensated pressure values. In some examples, controller 118 can be a microcontroller such as part no. ATMEGA8L-8AU, manufactured by Atmel Corporation of San Jose, Calif.

Transmitter 116 can be electrically coupled to sensor units 130 and 131 and controller 118. In some examples, transmitter 116 communicates the temperature-compensated pressure values provided by controller 118 to receiver 121 of computational unit 120. In other examples, transmitter 116 transmits the raw pressure and temperature measurements to receiver 121. In still other examples, transmitter 116 can communicate the temperature-compensated pressure values provided by controller 118 along with the raw pressure and temperature measurements to receiver 121.

In some examples, transmitter 116 can be a wireless transmitter, and receiver 121 can be a wireless receiver. In some examples, electrical signals can be transmitted using WI-FI (wireless fidelity), the IEEE (Institute of Electrical and Electronics Engineers) 802.11 wireless protocol or the Bluetooth 3.0+HS (High Speed) wireless protocol. In further examples, these signals can be transmitted via a Zigbee (802.15.4), Z-Wave, or a proprietary wireless standard. In other examples, transmitter 116 can transmit electrical signals using a cellular or wired connection.

HVAC system 250 is a device used to circulate heated, cooled, filtered, or conditioned air throughout a space (e.g., a house, an apartment, or an office). Although central home HVAC systems are not as prevalent in some geographic regions as plumbing or electrical infrastructure, a significant number of homes or buildings have central HVAC systems.

Because central HVAC systems are more efficient than using a collection of window units, the upward trend in energy cost has driven the use of central HVAC systems to a growing number of homes. In 1997, 66% of the homes in the United States and Canada were reported to have central HVAC systems, and its prevalence is growing at a fast rate. In addition, nearly all new homes built in the southern part of the U.S. and 80% in the rest of the U.S. and Canada have central HVAC systems installed during construction. Europe and Australia show a similar trend, with approximately 55% of homes using central HVAC systems. Regardless of the regional prevalence of central HVAC systems, the value of motion detection device **100** becomes more apparent in larger homes or in assisted living facilities that have many rooms, precisely the settings where installing many distributed sensors is economically unattractive.

HVAC systems will probably increase in prevalence because they can provide more functionality than just heating and cooling. Recent EnergyStar reports have shown that running the HVAC for longer periods of time, but using alternate conditioning features, such as an air-to-air exchanger, is more energy efficient. This EnergyStar report also recommends that HVAC systems incorporate whole house HEPA (high efficiency particulate absorbing) filtration. Construction codes, such as for hospitals and assistive care facilities, also have a minimum air movement requirements to ensure proper filtration. All of these factors increase the motivation for having the HVAC systems in operation, increasing the effectiveness of our sensing approach. Running the air handler's fan of a standard 2-ton (24,000 BTU (British Thermal Units)) HVAC system continuously for an entire month would cost about \$6 US (assuming an electricity price of \$0.05 US per 1 kW-h (kilowatts per hour)), which would need to be balanced against any value-added capability motion detection device **100** provides. As used herein, HVAC system refers to a heating system alone, a ventilation system alone, an air conditioning system alone or a combined heating, ventilation, and air conditioning system.

As illustrated in FIGS. 2 and 3, HVAC system **250** can include: (a) air handler **253**; (b) one or more return vents **251**; (c) one or more supply vents **255**; (d) ducts **361** (FIG. 3) coupling return vents **251** to air handler **253**; and (e) ducts **362** (FIG. 3) coupling air handler **253** to supply vents **255**.

As illustrated in FIG. 2, air handler **253** can include: (a) a blower **259**; (b) heating/cooling coils **254**; (c) air filter **252**; and (d) dampers (not shown). In some examples, blower **259**, heating/cooling coils **254**, air filter **252**, and the dampers can be located in a large, non-permanently sealed box **363** (FIG. 3). In other examples, air filter **252** can be located at other points in HVAC system **250**. For example, air filter **252** can be located at one of return vents **251**.

During its operation, a pressure differential, ΔP , known as the total static pressure, is built up in blower **259**. The total static pressure is a measure of resistance imposed on blower **259** in air handler **253**. The total static pressure is affected by a variety of factors that impede the airflow between the return vents **251** and supply vents **255**. These factors include the length of ducts **361** and **362**, the number of fittings used in ducts **361** and **362**, closed air vents, and/or dirty air filters. When installing HVAC system **250**, a technician usually takes care in properly balancing the total static pressure to ensure its proper operation. This balance includes installing sufficient supply ducts **361** and return ducts **362** in proper locations. Technicians also install ductwork to various rooms to ensure effective coverage. FIG. 3 shows a partial cross-sectional

drawing of a home and example locations of the return vents **251** and supply vents **255** and the potential associated airflow paths.

When HVAC system **250** is running, air flows from supply vents **255** to return vents **251** through the conditioned space (e.g., a room). There is typically some airflow from each of return vents **251** to all supply vents **255**. Depending on the location of vents **251** and **255**, the airflow paths and amount of airflow can vary. When there is disruption to the airflow, there is a change in the total static pressure in air handler **253** as a result of the resistance in the airflow. Depending on the location of supply vents **255**, a disruption in airflow can cause a more persistent change in the overall static pressure, such as from a direct blockage of a return vent. One contributor to this airflow disruption is doorways, where airflow can either be disrupted by the closing or opening of a door or the partial blockage of an adult passing through the threshold. Sometimes, an individual may even feel the "resistance" from the airflow when trying to open a door. Also, depending on the location in the house where this disruption is occurring, the "resistance" differs because the airflow path to air handler **253** is different.

When HVAC system **250** is not in operation, ducts **361** and **362** act as a pipe or wave guide. Significant airflow produced in the space flows through the ductwork. Although small movements might not generate enough airflow, the movements of large surfaces, such as doors, can produce detectable amounts of airflow through air handler **253**. Thus, there are opportunities to detect certain movement in the space when HVAC system **250** is in operation and also when HVAC system **250** is not in operation.

In various embodiments, sensing device **110** (FIG. 1) is configured to couple to air filter **252** of HVAC system **250** in FIG. 2. Air filter **252** can include: (a) a fibrous material **274**; and (b) an outer frame **276**. Air filter **252** can also have a first side **257** through which an air flow enters fibrous material **274** and a second side **258** opposite first side **257** and through which the air flow exits fibrous material **274**. In some examples, sensor unit **130** can be disposed proximate to or coupled to first side **257**, and sensor unit **131** be disposed proximate to or coupled to the second side **258**. In the same or different example, fibrous material can be replaced with a metallic mesh or screen, particularly when air filter **252** is an electrostatic air filter.

In some examples, sensing device **110** can use coupling device **132** (FIG. 1) to couple to air filter **252** (FIG. 2). In some examples, coupling device **132** can include complementary magnets where a first magnet is attached to sensor unit **130** and a second magnet is coupled to sensor unit **131**. The magnetic force between the magnets can be used to hold sensor unit **130** and the first magnet to first side **257** and sensor unit **131** and the second magnet to second side **258**.

In other examples, coupling device **132** can be a C-shaped housing **275** (FIG. 2) with sensor units **130** and **131** located at opposite ends of the housing. The C-shaped housing **275** can be configured such that C-shaped housing **275** can couple to air filter **252** where a first end with sensor unit **130** is located at first side **257** and a second end with sensor unit **131** is located at second side **258**.

In other examples, a single differential pressure sensor also would be appropriate. However, using two pressure sensors allows easier placement of the pressure sensor because an air tube would have to be routed through or around air filter **252** to allow the single differential pressure sensor to obtain pressure readings on both sides **257** and **258** of air filter **252**.

In some examples, air filter **252** is used as the sensing point for two reasons. First, air filter **252** can be located between the

return vents **251** and, in some examples, near blower **259**, making it a good place for recording the static pressure changes. Second, air filter **252** typically has the easiest access to the air handler **253**, making it potentially easier to deploy for installers and end-users. Coupling sensing device **110** to air filter **253** (or blower **259**) can be considered to be placing sensing device **110** in the ductwork of HVAC system **250**.

Referring again to FIG. 1, computational unit **120** is configured to use the two or more pressure measurements from sensor units **130** and **131** to determine when one or more movement events have occurred. Computational unit **120** can include: (a) transceiver or receiver **121**; (b) a processing module **122**; and (c) storage module **126**. As an example, processing module **122** can be one or more software programs. In some examples, processing module **122** can include: (a) a training module **123** configured to correlate events with changes in the total static pressure; (b) an event detection module **124** configured to use the two or more pressure measurements to identify changes in the total static pressure; and (c) a communications module **125** configured to communicate with a user. Receiver **121** can be configured to receive at least one of the temperature-compensated pressure and/or the raw pressure and temperature measurements from transmitter **116**.

“Computational Unit **120**,” as used herein, can refer to a single computer, single server, or a cluster or collection of computers and/or servers. In some examples, computational unit **120** can be local to the user. In other examples, the user can access computational unit **120** through the Internet or other networks.

In some examples, computational unit **120** can be a home computer of the user of motion detection device **100** or a computer owned or controlled by the owner of the building in which motion detection device **100** is installed. In other examples, a first server or computer (e.g., a home computer) can include a first portion of receiver **121**, storage module **126**, training module **123**, event detection module **124**, and communications module **125**. One or more second servers (e.g., a computer or server owned or controlled by the manufacturer of motion detection device **100** or a utility company or a security monitoring company) can include a second, possibly overlapping, portion of these modules. In these examples, computational unit **120** can comprise the combination of the first computer and the one or more second servers. In some examples, storage module **126** can store the correlation information between changes in the static pressure and specific movement events.

Event detection module **124** can determine the static air pressure by calculating the differential (ΔP) between the pressure measurement at sensor units **130** and **131** located at sides **257** and **258**, respectively, of air filter **252** (FIG. 2). In many embodiments, event detection module **124** can detect this phenomenon by first looking for a significant change in the static pressure in the pressure measurements from sensor units **130** and **131**. For example, event detection module **124** can compare the average of the five previous pressure differential readings with the current pressure differential measurement to attempt to detect a change in the total static pressure. When there is a pressure change greater than a predetermined or threshold amount (e.g., 10 mbar), event detection module **124** can record the subsequent pressure values for further processing until there are no more changes for a predetermined amount of time (e.g., 4,000 milliseconds). In some examples, a 10 mbar threshold change is used to avoid detecting any slight variations in HVAC fan speed from sensor units **130** and/or **131** or noise from analog-to-digital converter(s) inside sensor units **130** and **131**.

From the recorded data, event detection module **124** can extract the initial pressure value, the initial maximum pressure change, and the resulting final stable pressure. These features are extracted from the pressure measurements of sensor units **130** and **131** and produce a final feature vector of three components, which can be used in event classification (described in detail below).

For example, FIG. 4 shows a graph **400** of the change in static pressure versus time as a door is opened and closed. As illustrated in FIG. 4, there is an initial spike in the static pressure followed by a flattening as the door is closed. After the door is reopened, the pressure returns to the previous state. That is, two important features characterize door opening and closing events in the pressure measurements of sensor units **130** and **131**. When a door is closed, there is first an initial abrupt change in static pressure (i.e., a change in ΔP) followed by persistent change until the door is reopened. After opening the door, the static pressure gradually drops to the previous state.

In another example, FIG. 5 shows a graph **500** of the change in static pressure versus time as people walk through a doorway. Like opening and closing of door events, variations in the static pressure occur as individuals moved through various doorways. A person passing through a doorway, however, is a brief event, and unlike the door events, the changes in pressure are very short-lived. As shown in FIG. 5, usually there is a slight change in the static pressure, and then the pressure settles back to its original state. The size of the change in static pressure can be dependent on the location of the supply and return vents relative to the doorway and the ratio of the size of the person to the size of the doorway. In some implementations of motion detecting device **100**, observations showed that three out of four people passing through a door events resulted in detectable airflow disruptions (e.g., a change in static pressure of greater than ten millibars).

When HVAC system **250** is not operating, there is no static pressure build-up in air handler **253**. Instead, the pressure is equal to the atmospheric pressure of approximately one bar. Any significant airflow generated in the conditioned space is guided through either ducts **361** and **362** (FIG. 3) and eventually reaches the sensor units **130** and **131** (FIG. 2). The sensitivity of sensor units **130** and **131** make it possible to detect this airflow reaching sensor units **130** and **131**.

When HVAC system **250** is off, event detection module **124** (FIG. 1) can use the same or a similar method as when HVAC is on to determine when a movement event has occurred. Furthermore, when HVAC is off, event detection module **124** can use the pressure measurement from both sides of air filter **252** to help determine where the airflow originated.

It is also possible for event detection module **124** to detect airflow caused by people moving near an air vent and by other devices, such as a ceiling or desk fan. These movement events produce very small amounts of airflow and thus, require more expensive, high-resolution, and low-noise pressure sensors.

Training module **123** (FIG. 1) can be configured to correlate specific changes in pressure with specific events at specific locations. For example, training module **123** can be configured to determine that the movement event shown in FIG. 4 is the closing and opening of door leading into the master bedroom from the master bathroom.

In some examples, training module **123** can be configured to perform a training or calibration sequence to correlate changes in static pressure with specific movement events at specific locations. After performance of the calibration sequence, training module can provide the training correlation data to event detection module **124** so event detection

11

module **124** correlate the changes in static pressure with specific movement events at specific locations. Specific training or calibration sequences are described in relation to activity **920** of method **900** in FIG. 9.

Communications module **125** (FIG. 1) can be used to communicate and receive information to one or more users of motion detecting device **100**. For example, a user can use communications module **125** to enter information during a training or calibration sequence. Additionally, communications module **125** can inform a user when a movement event occurs. In some embodiments, communications module **125** can use monitor **1606**, keyboard **1604**, and/or mouse **1610** of FIG. 16.

Turning to another embodiment, FIG. 6 illustrates an implementation of sensing device **610** of a motion detecting device **600** in an exemplary HVAC system **650**, according to a second embodiment. Motion detecting device **600** is merely exemplary and is not limited to the embodiments presented herein. Motion detecting device **600** can be employed in many different embodiments or examples not specifically depicted or described herein. For example, motion detecting device **600** can be deployed in HVAC systems in a commercial or residential setting not specifically depicted or described herein.

In this example, motion detecting device **600** can include: (a) sensing device **610**; and (b) computational unit **120** (FIG. 1). Sensing device **610** can be part of air filter **653**. For example, air filter **653** can include: (a) filter and/or fibrous material **274**; (b) an outer frame **676** located around fibrous material **274**; (c) at least one sensor unit **130** and **131** coupled to at least one of fibrous material **274** or outer frame **676**; (c) a transmitter **116** (FIG. 1) electrically coupled to the sensor units **130** and **131**; (d) power source **117** (FIG. 1); and (e) controller **118** (FIG. 1). In this embodiment, at least one sensor unit **130** and **131** can be integral with air filter **653**. In some examples, air filter **653** is removable from HVAC system **650**, and/or fibrous material **274** is replaced with a wire mesh or screen. Other components of sensing device **610** can be similar to sensing device **110** (FIG. 1), and also can be part of air filter **653**. In the same or different embodiment, computational unit **120** can be part of or separate from air filter **653**. In some examples, the combination of sensing device **610** and air filter **653** can be considered a smart air filter, as opposed to sensing device **110** (FIG. 1), which can be considered, in some examples, to be a retrofit to HVAC system **250** (FIG. 2).

Turning to yet still another embodiment, FIG. 7 illustrates an implementation of sensing device **710** of a motion detecting device **700** in an exemplary HVAC system **750**, according to a third embodiment. Motion detecting device **700** is merely exemplary and is not limited to the embodiments presented herein. Motion detecting device **700** can be employed in many different embodiments or examples not specifically depicted or described herein. For example, motion detecting device **700** can be deployed in HVAC systems in a commercial or residential setting not specifically depicted or described herein.

In this example, motion detecting device **700** can include: (a) sensing device **710**; and (b) computational unit **720**. Sensing device **710** could be integrally and/or permanently part of a HVAC system. For example, sensing device **710** (or sensor units **130** and/or **131**) can be located at or in blower **759**. In some embodiments, computational unit **720** can be also located inside HVAC system **750** (e.g., inside large, non-permanently sealed box **363** (FIG. 3)). In some examples, sensing device **710** and computational unit **720** can be similar

12

to sensing device **110** (minus coupling device **132** (FIG. 1)) and computational unit **120**, respectively.

FIG. 8 illustrates a flow chart for an embodiment of a method **800** of providing a motion sensor, according to an embodiment. Method **800** is merely exemplary and is not limited to the embodiments presented herein. Method **800** can be employed in many different embodiments or examples not specifically depicted or described herein. In some embodiments, the activities, the procedures, and/or the processes of method **800** can be performed in the order presented. In other embodiments, the activities, the procedures, and/or the processes of the method **800** can be performed in any other suitable order. In still other embodiments, one or more of the activities, the procedures, and/or the processes in method **800** can be combined.

Method **800** of FIG. 8 includes an activity **810** of providing one or more pressure sensors configured to provide two or more pressure measurements. As an example, the one or more pressure sensors can be similar or identical to pressure sensors **112** and/or **114** or sensor units **130** and/or **131** of FIG. 1.

Method **800** in FIG. 8 continues with an activity **815** of providing a transmitter. As an example, the transmitter can be similar or identical to transmitter **116** of FIG. 1.

Subsequently, method **800** of FIG. 8 includes an activity **820** of providing a controller. As an example, the controller can be similar or identical to controller **118** of FIG. 1.

Next, method **800** of FIG. 8 includes an activity **825** of electrically coupling the one or more pressure sensors to the controller and the one or more pressure sensors. For example, the one or more pressure sensors can be electrically coupled to the controller and the one or more pressure sensors in a manner similar or identical to the electrical coupling of sensor units **130** and **131** to controller **118** and to sensor units **130** and **131**, as illustrated in FIG. 1.

Method **800** in FIG. 8 continues with an activity **830** of electrically coupling the transmitter to the controller and the one or more pressure sensors. For example, the transmitter can be electrically coupled to the controller in a manner similar or identical to the electrical coupling of transmitter **116** to controller **118**, as illustrated in FIG. 1.

Subsequently, method **800** of FIG. 8 includes an activity **835** of providing a body. In some examples, the body can be identical or similar to C-shaped housing **275** of FIG. 2, box **363** of FIG. 3, or air filter **653** of FIG. 6.

Next, method **800** of FIG. 8 includes an activity **840** of mechanically coupling the one or more pressure sensors, the transmitter, and the controller to the body.

Method **800** in FIG. 8 continues with an activity **845** of providing a computational unit. In some examples, the computational unit can include: (a) a receiver; (b) an event detection module configured to use the two or more pressure measurements to determine when one or more movement events have occurred; and (c) a training module configured to determine a relationship between the two or more pressure measurements and the one or more movement events. As an example, the computational unit can be similar or identical to computational unit **120** of FIG. 1. The receiver, the event detection module, and the training module can be similar or identical to receiver **121**, event detection module **124**, and training module **123** of FIG. 1, respectively.

FIG. 9 illustrates a flow chart for an embodiment of a method **900** of detecting movement, according to an embodiment. Method **900** is merely exemplary and is not limited to the embodiments presented herein. Method **900** can be employed in many different embodiments or examples not specifically depicted or described herein. In some embodiments, the activities, the procedures, and the processes of

13

method **900** can be performed in the order presented. In other embodiments, the activities, the procedures, and the processes of the method **900** can be performed in any other suitable order. In still other embodiments, one or more of the activities, the procedures, and the processes in method **900** can be combined. In yet further examples, one or more of the activities, the procedures, and the processes in method **900** can be combined with one or more of the activities, the procedures, and the processes in method **800** of FIG. **8**.

Method **900** of FIG. **9** includes an activity **910** of receiving first pressure data in one or more pressure sensors. As an example, the one or more pressure sensors can be similar or identical to pressure sensors **112** and **114** or sensor units **130** and **131** of FIG. **1**.

Method **900** in FIG. **9** continues with an activity **915** of transmitting the first pressure data to a first computational unit. In some examples, a transmitter can wireless transmit electrical signals using WI-FI, the Bluetooth 3.0+HS wireless protocol, Zigbee, Z-Wave, or a cellular network. In other examples, the transmitter can transmit the first pressure data over a wired connection.

Subsequently, method **900** of FIG. **9** includes an activity **920** of using the first pressure data to train the first computational unit to correlate the first pressure data to one or more specific movement events. In some examples, training module **123** (FIG. **1**) can perform a training or calibration process with a user.

Referring back to FIG. **1**, in various embodiments, the calibration process can involve a labeling process where a user of motion detecting device **100** helps relate changes in static pressure to specific movement events at specific locations. In some embodiments, the training sequence involves a user of motion detecting device **100** walking through the house or building while training module **123** is operating and recording movement events.

After walking through the house or building, the user can label each movement event detected by training module **123** using communications module **125**. For example, if the user started in a main hallway and walked: (1) through a first doorway from the main hallway into a family room and (2) from the family room into the kitchen through a second doorway, a first movement event detected by motion detecting device **100** can be labeled as person walking from the main hallway into a family room, and a second movement event detected by motion detecting device **100** can be labeled as a person walking from the family room into the kitchen through a second doorway. Similarly, a user can open and close all of the doors in the housing or building and perform a similar labeling procedure.

In other examples, communications module **125** can include a portion that can run on a mobile electrical device (e.g., an iPhone® device by Apple Computers, Inc. of Cupertino, Calif.) that allows a user to mark or timestamp when a specific movement event occurred. In these examples, a user could walk through the house or building while carrying the electrical device running the part of communications module **125** and use communications module **125** to mark when a movement event occurred.

For example, while training module **123** is operating and recording movement events, the user can walk through a first doorway from a main hallway into a family room and press a button on the mobile electrical device that causes the electrical device to record the description of the movement event and the time that event occurred. Training module **123** can correlate the data recorded by the mobile electrical device and the static pressure changes detected by sensing devices **110** and **112** to relate changes in static pressure to specific move-

14

ment events at specific locations. In some examples, the mobile electrical device can relay the data immediately (e.g., in real time) to computational unit **120**, and in other examples, the data can be communicated to computational unit **120** after the training process is complete (e.g., in batch mode).

In some embodiments, the user will have to perform the training process twice, once with the HVAC system on and once with the HVAC system off. In the same or different embodiments, the training process can be performed multiple times to increase the accuracy of the results of the training process.

Referring again to FIG. **9**, method **900** of FIG. **9** includes an activity **925** of receiving second pressure data from the one or more pressure sensors. In some examples, activity **925** can be similar or identical to activity **910**.

Method **900** in FIG. **9** continues with an activity **930** of transmitting the second pressure data to the first computational unit. In some examples, activity **930** can be similar or identical to activity **915**.

Subsequently, method **900** of FIG. **9** includes an activity **935** of correlating the second pressure data to a first event of the one or more specific movement events. Referring again to FIG. **1**, to classify events, event detection module **124** can use the training data. That is, event detection module **124** can use a method of matching movement events with the movement events recording during the training process. For example, every time a specific door is opened or a person walks a specific doorway, the static pressure signature of the movement event will be substantially the same. Accordingly, event detection module **124** can match a static pressure signature of the just occurred movement event with the static pressure signature of the training process to identify the just occurred movement event.

To classify events, event detection module **124** can use a support vector machine (SVM) models in some embodiments. SVM models perform classification by constructing an N-dimensional hyperplane that optimally separates the data into multiple categories. The separation is chosen to have the largest distance from the hyperplane to the nearest positive and negative examples. Thus, the classification is appropriate for testing data that is near, but not identical, to the training data as is the case for the feature vectors in this embodiment. In addition, SVMs can automatically determine the appropriate kernel type based on the data build characteristics, so kernels beyond linear functions can be factored into the determination. For example, three different SVM models can be used for each of the three scenarios (e.g., opening and closing of doors while the HVAC is in operation, adults moving through doorways while the HVAC is in operation, and the opening and closing of doors while the HVAC is not in operation), using their respective feature vectors with each transition event labeled as the class.

In the same or different example, a map or diagram of the home or building can be imported or loaded into computational unit **120**. The training module (such as training module **123** in FIG. **1**) can use the map or diagram to help identify the event. For example, event detection module **124** determines that a person just walked into a first room and then determines a second movement event occurred. After performing the matching process, event detection module **124** determines the second movement event is most likely one of a person walking into one of two rooms. According to the map of the house, one of the rooms is adjacent to the first room in which the person just walked and the other room is at the other side of the building. In this case, event detection module **124** can reasonably conclude using information from the map or dia-

15

gram of the building, it is most likely that the person just walked into the room adjacent to the first room.

Referring again to FIG. 9, method 900 of FIG. 9 includes an activity 940 of displaying information regarding the first event to a user. In some examples, communications module 125 (FIG. 1) can inform a user when a movement event occurs or provide information about two or more movement events. In some embodiments, communications module 125 (FIG. 1) can use monitor 1606, keyboard 1604, and/or mouse 1610 of FIG. 16.

In other examples, communications module 125 can provide the information to other systems. For example, the information can be provided to a system that controls the HVAC system for use in, for example, turning on or off the HVAC system in parts of the home or building (e.g., zone heating and cooling). In another example, the information about specific events can be provided to an alarm system. In yet another embodiment, the information about specific movement events can be provided to a system that monitors and controls electricity usage in the home or building. In further embodiments, the information can be provided to a system that controls the lights and other electrical outlets. In this embodiment, the information can be used, for example, to turn on lights and other electrical appliances in the room the person just entered and to turn off the lights and other electrical appliances in the room the person just exited.

Several feasibility experiments were performed as part of the development of embodiments of motion detecting device 100 and methods 800 and 900. The goal of these feasibility experiments was to determine if and how often motion detecting device 100 could detect movement events (e.g., adults walking through doorways and the opening and closing of doors) and how accurately motion detecting device 100 could classify unique movement events.

In this section, results are presented from these experiments in four different homes for the following three conditions: (a) opening and closing of doors while the HVAC is in operation, (b) adults moving through doorways while the HVAC is in operation, and (c) the opening and closing of doors while the HVAC is not in operation.

Observations were conducted in four different homes for a period ranging from three to four weeks (see Table 1 in FIG. 10 for information about the homes). Home 1 and Home 2 were fairly large homes, with Home 1 having three separate central HVAC units, and Home 2 having two separate central HVAC units. All three units in Home 1 and one unit in Home 2 were instrumented with an embodiment of motion detecting device 100 in FIG. 1. Homes 3 and 4 were smaller apartments with a single, central HVAC system. Thus, a total of six different spaces and HVAC units were evaluated. For each HVAC unit, an embodiment of motion detecting device 100 was installed at the air filter. Five pressure sensors were securely attached to an air filter prevent any movement from the airflow. The sensing device was coupled to a computation device with cables. Cables were run around the edge of the air filter to prevent them from being drawn in to the fan assembly. Finally, the cables were connected to a computational unit (e.g., a laptop) placed near the HVAC system.

Two techniques for obtaining labeled training data were used. First, throughout the 3-4 week period while the houses were in a closed and sealed state (windows and exterior doors closed), numerous door close and open events, and a person walking through doorways events were manually labeled. Second, data was captured for a longer time period using traditional motion sensors placed at various locations in the house. The traditional motion sensors were placed on both sides of the top of the doorways (facing downwards) to

16

detected movement events and the direction of movement through the door. These motion sensors allowed determination of any movement events that occurred at various times during the day. The large dataset created allowed portioning of the data into training and test sets.

In these experiments, the feasibility of accurately classifying the various kinds of movement events in a quasi-controlled manner was tested. For all four homes, sensor readings were manually labeled for each event using a remote handheld computer wirelessly connected to the computational unit. Accurately labeling the sensor readings for each of the five sensors after triggering the various events was found to be possible. The method described above (e.g., activity 935 of FIG. 9), were used to construct the appropriate feature vectors to feed the classifier data. For these experiments, all interior doors of interest were kept in the open position (90 degrees from the opening), and then each of such doors were manually and sequentially or individually opened and closed. For the human movement experiments, the same individual triggered those events. Twenty-five instances for each of the doorway events were collected at three different times during the 3-4 week period.

Table 2 in FIG. 11 shows the classification accuracies of all the spaces. A sample confusion matrix is also included in Table 3 of FIG. 12. It is clear that door transition movement events were more accurately detected than people transition movement events. However, the overall accuracy of classifying unique movement events was around 65%. Door events were classified correctly on an average of 75-80% of the time. Both of these events can be combined to provide good predictions on the location or movement of people through the space. Some of the low classification accuracies, such as from Floor 2 in Home 1, were attributed to the lack of doors and doorways and that the space in Floor 2 of Home 1 was very open with the air vent a significant distance away from the interior doors. The results of the HVAC off experiment are also shown in Table 4 of FIG. 13. The higher performance came in smaller spaces where the vents tended to be closer to the doorway and also came in spaces where there were many vents, such as Homes 1 and 2.

For the long-term deployment, more in-situ or "more natural" data on the various events occurring in the home was collected, and this data provided some initial long-term in-situ results. For labeling, motion sensors placed at various doorways were used to determine any door movement or motion through the doorway and matched up those events with the corresponding sensor values from the HVAC system.

Two analyses were conducted: (a) one was the percentage of time motion detecting device 100 was able to determine particular events; and (b) the second were to determine the classification accuracies of detecting unique events. Table 5 of FIG. 14 shows the number of events that were detected by motion detecting device 100, either as a door transition event or a human movement through the doorway, for each of the four homes. The results for two cases are presented: one is with the HVAC system in operation and the other is with the HVAC system off.

The results show that a larger percentage of events were detected with the HVAC system in operation than with the HVAC system in the off state. The reason for the lower percentage for the HVAC system off state was because of the location of the return and supply vents. In some cases, the vents were not close enough to a door for the airflow to reach the sensing units, which was also observed in the controlled experiment. The smaller spaces and the spaces with many doorways actually resulted in a higher number of detectable events. This characteristic is attributed to the greater number

17

of vents and the likelihood that the doorways were near vents. The results with the HVAC system in operation showed almost 80% of the events being detected when compared to the traditional motion sensors.

Table 6 of FIG. 15 shows the results of classifying unique events in the house. The SVM classification scheme was applied to the entire in situ dataset for each of the 4 homes (6 spaces). This dataset included events from all three of the possible conditions (door open/close with HVAC on and off and human movement with HVAC on). The triggering of the motion sensor was used to provide the location label to the air pressure data collected by our sensing system. Because the type of event was not known, the signal response was used to determine the event (i.e., person or door).

The accuracy of motion detecting device 100 is shown using 10-fold cross validation across the entire data set. Compared to the first controlled experiments, the overall accuracy on average is 15-20% lower. However, given that no control existed over the various other events occurring during that same time, the results still showed classification accuracies between 60-70%. From this data, it is clear the status of other doors in the home did not have a large impact on the classification accuracy of detecting door transitions with the HVAC system off. The larger difference while the HVAC system is in operation compared to the controlled experiment does indicate that the door states have an impact on the pressure differentials, as expected.

FIG. 16 illustrates a computer 1600 that is suitable for implementing an embodiment of at least a portion of processing module 122 (FIG. 1). Computer 1600 includes a chassis 1602 containing one or more circuit boards (not shown), a floppy drive 1612, a Compact Disc Read-Only Memory (CD-ROM) and/or Digital Video Disc (DVD) drive 1616, and a hard drive 1614. A representative block diagram of the elements included on the circuit boards inside chassis 1602 is shown in FIG. 17. A central processing unit (CPU) 1710 in FIG. 17 is coupled to a system bus 1714 in FIG. 17. In various embodiments, the architecture of CPU 1710 can be compliant with any of a variety of commercially distributed architecture families including the ARM (advanced RISC (reduced instruction set) computing machine), MIPS (microprocessor without interlocked pipeline stages), RS/6000 family, the Motorola 68000 family, or the Intel x86 family.

System bus 1714 also is coupled to memory 1708 that includes both read only memory (ROM) and random access memory (RAM). Non-volatile portions of memory 1708 or the ROM can be encoded with a boot code sequence suitable for restoring computer 1600 (FIG. 16) to a functional state after a system reset. In addition, memory 1708 can include microcode such as a Basic Input-Output System (BIOS). In some examples, memory 1708 can include floppy drive 1612, hard drive 1614, and/or CD-ROM or DVD drive 1616 storage module 126 (FIG. 1).

In the depicted embodiment of FIG. 17, various I/O devices such as a disk controller 1704, a graphics adapter 1724, a video controller 1702, a keyboard adapter 1726, a mouse adapter 1706, a network adapter 1720, and other I/O devices 1722 can be coupled to system bus 1714. Keyboard adapter 1726 and mouse adapter 1706 are coupled to keyboard 1604 (FIGS. 16 and 17) and mouse 1610 (FIGS. 16 and 17), respectively, of computer 1600 (FIG. 16). While graphics adapter 1724 and video controller 1702 are indicated as distinct units in FIG. 17, video controller 1702 can be integrated into graphics adapter 1724, or vice versa in other embodiments. Video controller 1702 is suitable for refreshing a monitor 1606 (FIGS. 16 and 17) to display images on a screen 1608 (FIG. 16) of computer 1600 (FIG. 16). Disk controller 1704 can

18

control hard drive 1614 (FIGS. 16 and 17), floppy disc drive 1612 (FIGS. 16 and 17), and CD-ROM or DVD drive 1616 (FIGS. 16 and 17). In other embodiments, distinct units can be used to control each of these devices separately.

Although many other components of computer 1600 (FIG. 16) are not shown, such components and their interconnection are well known to those of ordinary skill in the art. Accordingly, further details concerning the construction and composition of computer 1600 and the circuit boards inside chassis 1602 (FIG. 16) need not be discussed herein.

When computer 1600 in FIG. 16 is running, program instructions stored on a floppy disc in floppy disc drive 1612, on a CD-ROM or DVD in CD-ROM and/or DVD drive 1616, on hard drive 1614, or in memory 1708 (FIG. 17) are executed by CPU 1710 (FIG. 17). A portion of the program instructions, stored on these devices, can be suitable for carrying out at least part of method 900 (FIG. 9).

Although the invention has been described with reference to specific embodiments, it will be understood by those skilled in the art that various changes may be made without departing from the spirit or scope of the invention. Accordingly, the disclosure of embodiments of the invention is intended to be illustrative of the scope of the invention and is not intended to be limiting. It is intended that the scope of the invention shall be limited only to the extent required by the appended claims. For example, to one of ordinary skill in the art, it will be readily apparent that a sensing device can include any number of sensor units, and that activities 810, 815, 820, 825, 830, 835, 840, and 845 of FIG. 8, activities 910, 915, 920, 925, 930, 935, and 940 of FIG. 9 or any element of FIGS. 1, 6 and/or 7 may be comprised of many different activities, procedures and be performed by many different modules, in many different orders and that the foregoing discussion of certain of these embodiments does not necessarily represent a complete description of all possible embodiments.

All elements claimed in any particular claim are essential to the embodiment claimed in that particular claim. Consequently, replacement of one or more claimed elements constitutes reconstruction and not repair. Additionally, benefits, other advantages, and solutions to problems have been described with regard to specific embodiments. The benefits, advantages, solutions to problems, and any element or elements that may cause any benefit, advantage, or solution to occur or become more pronounced, however, are not to be construed as critical, required, or essential features or elements of any or all of the claims.

Moreover, embodiments and limitations disclosed herein are not dedicated to the public under the doctrine of dedication if the embodiments and/or limitations: (1) are not expressly claimed in the claims; and (2) are or are potentially equivalents of express elements and/or limitations in the claims under the doctrine of equivalents.

What is claimed is:

1. A motion detecting device configured to detect movement by at least one person, animal, or one or more interior doors inside of a multi-room structure, the multi-room structure comprising a heating, ventilation, and air conditioning system, the heating, ventilation, and air conditioning system comprising an air handler configured to be located in a non-permanently sealed box in the multi-room structure, the motion detecting device comprises:

a processing module configured to run on a computational unit; and
a sensing device configured to be located in the air handler of the heating, ventilation, and air conditioning system,

19

the sensing device further configured to detect static air pressure inside the air handler at two or more times; wherein:

the sensing device comprises a first pressure sensor and a second pressure sensor;

the processing module is configured to use the static air pressure at the two or more times to determine whether movement within an interior of the multi-room structure by the at least one person, animal, or one or more interior doors inside of the multi-room structure has occurred; and

the processing module is further configured to use the static air pressure detected at the two or more times to determine if the movement was through a specific one of the one or more interior doors inside of the multi-room structure.

2. The motion detecting device of claim 1, wherein: the sensing device is configured to detect a first static air pressure measurement at a first time, a second static air pressure measurement at a second time, and a third static air pressure measurement at a third time; the first time is before the second time and the third time; the second time is before the third time; the processing module is configured determine whether movement by the at least one person, animal, or one or more interior doors inside of the multi-room structure has occurred by comparing the first static air pressure measurement, the second static air pressure measurement, and the third static air pressure measurement; and the static air pressure at the two or more times comprises the first static air pressure measurement, the second static air pressure measurement, and the third static air pressure measurement.

3. The motion detecting device of claim 1, wherein: at least a part of the sensing device is configured to be disposed proximate to an air filter located in the air handler.

4. The motion detecting device of claim 3, wherein: the air filter comprises: a first side through which an air flow enters the air filter; and a second side opposite the first side and through which the air flow exits the air filter; and the first pressure sensor of the sensing device is disposed proximate to the first side of the air filter; and the second pressure sensor of the sensing device is disposed proximate to the second side of the air filter.

5. The motion detecting device of claim 4, wherein: the first pressure sensor of the sensing device is configured to provide a first pressure measurement at substantially a first time; the second pressure sensor of the sensing device is configured to provide a second pressure measurement at substantially the first time; and the static air pressure at the two or more times comprises the first pressure measurement and the second pressure measurement.

6. The motion detecting device of claim 1, wherein: the processing module comprises: a training module; the training module is configured to correlate a first movement with a first change in pressure and a second movement with a second change in pressure.

7. The motion detecting device of claim 6, wherein: the processing module further comprises: an event detection module; the event detection module is configured to use the static air pressure at the two or more times to identify the move-

20

ment by the at least one person, animal, or one or more interior doors inside of the multi-room structure has occurred.

8. The motion detecting device of claim 7, wherein: the processing module further comprises: a communications module configured to communicate to a user.

9. The motion detecting device of claim 1, wherein: the sensing device comprises: one or more temperature sensors; and the sensing device is configured such that the one or more temperature sensors measure at least one temperature at the sensing device.

10. The motion detecting device of claim 9, wherein: the processing module is further configured to calculate a temperature-compensated pressure value for each of the static air pressure at the two or more times using the at least one temperature at the sensing device.

11. The motion detecting device of claim 1, wherein: the sensing device further comprises: a controller; and one or more temperature sensors; the sensing device is configured such that the one or more temperature sensors measure at least one temperature at the sensing device; and the controller is configured to calculate a temperature-compensated pressure value for each of the static air pressure at the two or more times using the at least one temperature at the first and second pressure sensors.

12. A method of detecting movement by at least one person, animal, or interior door of a multi-room structure within an interior of the multi-room structure, the method comprising: performing two or more first measurements of static air pressure in an air handler of an heating, ventilation, and air conditioning system, the air handler being located in a non-permanently sealed box in the multi-room structure; determining one or more first changes of the static air pressure based on the two or more first measurements of the static air pressure; and associating at least one of the one or more first changes of the static air pressure with movement by a specific one of the at least one person, animal, or interior door within the interior of the multi-room structure.

13. The method of claim 12, further comprising: performing two or more second measurements of the static air pressure from at least one of a duct of the heating, ventilation, and air conditioning system or the air handler of the heating, ventilation, and air conditioning system; determining one or more second changes of the static air pressure based on the two or more second measurements of the static air pressure; and associating one or more second movement events by the at least one person, animal, or interior door with the one or more second changes of the static air pressure.

14. The method of claim 12, wherein: the two or more first measurements of the static air pressure are performed by a differential pressure sensor located in the air handler.

15. The method of claim 12, wherein: the two or more first measurements of the static air pressure are each performed by two pressure sensors located in the air handler.

16. The method of claim 15, wherein: the two pressure sensors comprise: a first pressure sensor disposed at a first side of an air filter; and

21

a second pressure sensor disposed at a second side of the air filter opposite the first side of the air filter; and the air filter is located within the air handler.

17. A motion sensor comprises:

a processing module configured to run on a computational unit; and

a sensing device configured to be located in an air handler of a heating, ventilation, and air conditioning system, the air handler being located in a non-permanently sealed box in a multi-room structure, the sensing device further configured to detect static air pressure in the air handler at three or more times,

wherein:

the processing module is configured to correlate a first movement with a first change in the static air pressure and a second movement with a second change in the static air pressure;

the processing module is further configured to use the static air pressure at the three or more times to determine the first change in the static air pressure and the second change in the static air pressure;

the processing module is further configured to determine whether the first movement and the second movement were by a person or an animal; and

the processing module is further configured to determine a specific one of one or more interior doors inside of the multi-room structure that was involved in each of the first movement and the second movement.

18. The motion sensor of claim 17, wherein:

the sensing device is further configured to detect static air pressure at two or more second times; and

the processing module is configured to use the static air pressure at the two or more second times to determine that the person, the animal, or the one or more interior doors has moved inside of the multi-room structure.

19. The motion sensor of claim 17, wherein:

at least a part of the sensing device is configured to be disposed proximate to an air filter of the heating, ventilation, and air conditioning system.

20. The motion sensor of claim 17, wherein:

the sensing device is further configured to determine a temperature at the sensing device at the three or more times; and

the processing module is further configured to calculate a temperature-compensated pressure value for each of the static air pressure detected at the at three or more times using the temperature at the sensing device at the three or more times.

21. A method of providing a motion sensor for a multi-room structure, the multi-room structure has one or more interior doors and a heating, ventilation, and air conditioning system, the heating, ventilation, and air conditioning system comprising an air handler located in a non-permanently sealed box in the multi-room structure, the method comprising:

providing one or more pressure sensors configured to provide two or more static air pressure measurements within the air handler;

providing a transmitter;

electrically coupling the transmitter to the one or more pressure sensors;

providing a body;

mechanically coupling the one or more pressure sensors and the transmitter to the body; and

providing a processing module configured to run on a computational unit, the processing module comprising: an event detection module configured to use the two or more static air pressure measurements to correlate

22

one or more movement events with movement within an interior of the multi-room structure by at least one of a person, an animal, or a specific one of the one or more interior doors of the multi-room structure.

22. The method of claim 21, wherein:

providing the processing module further comprising:

a training module configured to determine a relationship between the two or more static air pressure measurements and the one or more movement events.

23. An air filter unit configured to be located within an air handler of a heating, ventilation, and air conditioning system, the air handler being located in a non-permanently sealed box in a multi-room structure, the air filter unit comprising:

an air filter comprising:

a filter material;

an outer frame located around the filter material;

at least one pressure sensor disposed proximate to at least one of the filter material or the outer frame and configured to provide two or more static air pressure measurements within the air handler; and

a transmitter electrically coupled to the at least one pressure sensor; and

a processing module configured to run on a computational unit, the processing module configured to determine an occurrence of one or more movement events in an interior of the multi-room structure by at least one person, animal, or interior door based on the two or more static air pressure measurements of the at least one pressure sensor.

24. The air filter unit of claim 23 further comprising:

a receiver coupled to the processing module and configured to receive electrical data from the transmitter,

wherein:

the air filter is separate from the processing module.

25. The air filter unit of claim 23, wherein:

the at least one pressure sensor is integral with the air filter.

26. The air filter unit of claim 23, wherein:

the at least one pressure sensor is removable from the air filter.

27. The air filter unit of claim 23, wherein:

the processing module is further configured to determine whether the occurrence of the one or more movement events was movement through a specific interior door of the at least one interior door of the multi-room structure.

28. A heating, ventilation, and air conditioning system comprising:

an air handler located in a non-permanently sealed box configured to be located in a multi-room structure;

at least one pressure sensor located in the air handler; and

a processing module configured to run on a computational unit, the processing module electrically coupled to the at least one pressure sensor via the computational unit and configured to determine an occurrence of one or more movement events in an interior of the multi-room structure by at least one person, animal, or interior door based on two or more static air pressure measurements inside the air handler from the at least one pressure sensor.

29. The heating, ventilation, and air conditioning system of claim 28, wherein:

the processing module is further configured to determine whether the occurrence of the one or more movement events was movement through a specific interior door of the at least one interior door of the multi-room structure.

* * * * *